

Evidence of Performance



Test report 10-000826-PB01-A01-02-en-01

Client Troha-dil d.o.o.
Poslovna "Zona-P" Severin


43274 Severin
Croatia

Basis

EN 14351-1:2006+A1:2010
Test standards:
EN 1026 : 2000-06
EN 1027 : 2000-06
EN 12211 : 2000-06
EN 12046-1 : 2003-11
Corresponds to the national standard. (DIN EN)

Product	Tilt and turn window
System	BLUEGREEN Exclusive
Overall dimensions (W x H)	1230 mm x 1480 mm
Frame material	Wood-Aluminium
Special features	Design with high resistance to water vapour diffusion according to ENV 13420.

Representation



Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1 shall be observed.

Resistance to wind load – EN 12210



Class C5

Watertightness – EN 12208



Class E750

Air permeability – EN 12207



Class 4

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 12 pages.

ift Rosenheim
10. January 2011

Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components

Andreas Graf, Dipl.-Ing. (FH)
Operating Testing Officer
Tightness & Wind Load



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Giell-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18

DAP-PL-0908 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60