

# Evidence of Performance



## Test report 10-000826-PB03-A01-02-en-01


Client Troha-dil d.o.o.  
Poslovna "Zona-P" Severin  
  
43274 Severin  
Croatia

### Basis

EN 14351-1:2006+A1:2010  
Test standards:  
EN 1026 : 2000-06  
EN 1027 : 2000-06  
EN 12211 : 2000-06  
EN 12046-1 : 2003-11  
Corresponds to the national standard. (DIN EN)

Product	Tilt and turn window
System	BLUEGREEN Plus
Overall dimensions (W x H)	1230 mm x 1480 mm
Frame material	Wood-Aluminium
Special features	Design with high resistance to water vapour diffusion according to ENV 13420.

### Representation



### Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1 shall be observed.

### Resistance to wind load – EN 12210



**Class C4**

### Watertightness – EN 12208



**Class E1200**

### Air permeability – EN 12207



**Class 4**

### Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

### Contents

The report contains a total of 12 pages.

ift Rosenheim  
10. January 2011

  
Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Components

  
Andreas Graf, Dipl.-Ing. (FH)  
Operating Testing Officer  
Tightness & Wind Load



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Giethl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
  
DAP-PL-0908 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60